## **SIEMENS**

**Data sheet** 



\*\*\*Spare part\*\*\* SIMATIC DP, CPU 1512SP-1 PN for ET 200SP, Central processing unit with Work memory 200 KB for program and 1 MB for data, 1st interface, PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required, BusAdapter required for Port 1 and 2

General information	
Product type designation	CPU 1512SP-1 PN
HW functional status	FS04
Firmware version	V1.8
Product function	
• Isochronous mode	Yes; Only with PROFINET; with minimum OB $6x$ cycle of $625~\mu s$
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	V13 SP1 Update 4
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Input current	
Current consumption (rated value)	0.6 A
Inrush current, max.	4.7 A; Rated value
l²t	0.14 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	200 kbyte
• integrated (for data)	1 Mbyte
Load memory	
Plug-in (SIMATIC Memory Card), max.	32 Gbyte
Backup	
• maintenance-free	Yes
CPU processing times	
for bit operations, typ.	48 ns
for word operations, typ.	58 ns

for fixed point arithmetic, typ.	77 ns
for floating point arithmetic, typ.	307 ns
PU-blocks	
Number of elements (total)	2 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1
-	59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	200 kbyte
FC	
Number range	0 65 535
• Size, max.	200 kbyte
OB	
• Size, max.	200 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	24
S7 counter	
Number	2 048
Retentivity	2 040
•	Yes
— adjustable	Tes
IEC counter	Any (and limited by the main manager)
Number  Potentials	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
S7 times	0.010
• Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
ata areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; Available retentive memory for bit memories, timers, counters, DBs,
-	and technology data (axes): 88 KB
Flag	4011.4
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
<ul> <li>per priority class, max.</li> </ul>	64 kbyte; max. 16 KB per block
Per priority dass, max.	
ddress area	
	2 048; max. number of modules / submodules

• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	32 byte; For input and output data respectively
Address space per station	
Address space per station, max.	1 280 byte; for central inputs and outputs; depending on configuration
Hardware configuration	
Number of distributed IO systems	20
Number of DP masters	20
Via CM	1
Number of IO Controllers	·
	1
• integrated	1
• Via CM	0
Rack	CALCELL CA modulos Logarias and de (annual and the
Modules per rack, max.	64; CPU + 64 modules + server module (mounting width max. 1 m)
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	31013
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
<ul><li>supported</li></ul>	Yes
<ul> <li>to DP, master</li> </ul>	Yes; Via CM DP module
	1 Co, Via Givi Di Modulo
• on DP, device	Yes; Via CM DP module
• in AS, master	
	Yes; Via CM DP module
• in AS, master	Yes; Via CM DP module Yes
<ul><li>in AS, master</li><li>in AS, device</li></ul>	Yes; Via CM DP module Yes Yes
<ul><li>in AS, master</li><li>in AS, device</li><li>on Ethernet via NTP</li></ul>	Yes; Via CM DP module Yes Yes
<ul> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> Interfaces	Yes; Via CM DP module Yes Yes Yes
<ul> <li>in AS, master</li> <li>in AS, device</li> <li>on Ethernet via NTP</li> </ul> Interfaces Number of PROFINET interfaces	Yes; Via CM DP module Yes Yes Yes 1
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces	Yes; Via CM DP module Yes Yes Yes 1
in AS, master in AS, device on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module
in AS, master in AS, device on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types RJ 45 (Ethernet)	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module Yes; X1
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)	Yes; Via CM DP module Yes Yes Yes 1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC
in AS, master in AS, device on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface  Interface types RJ 45 (Ethernet) Number of ports integrated switch BusAdapter (PROFINET)  Protocols PROFINET IO Controller	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication	Yes; Via CM DP module Yes Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server  Media redundancy	Yes; Via CM DP module Yes Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server  Media redundancy  PROFINET IO Controller	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes Yes
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server  Media redundancy  PROFINET IO Controller  Services	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
in AS, master  in AS, device  on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces  1. Interface  Interface  Interface types  RJ 45 (Ethernet)  Number of ports  integrated switch  BusAdapter (PROFINET)  Protocols  PROFINET IO Controller  PROFINET IO Device  SIMATIC communication  Open IE communication  Web server  Media redundancy  PROFINET IO Controller	Yes; Via CM DP module Yes Yes Yes  1 1; Via CM DP module  Yes; X1 3; 1. integr. + 2. via BusAdapter Yes Yes; Applicable BusAdapter: BA 2x RJ45, BA 2x FC  Yes Yes Yes Yes Yes Yes Yes

Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes
<ul> <li>Prioritized startup</li> </ul>	Yes; Max. 32 PROFINET devices
<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 253 distributed I/O devices can be connected via PROFIBUS or PROFINET
<ul><li>Of which IO devices with IRT, max.</li></ul>	64
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	Ŭ
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 μs of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs 3
with the and parameterization of our sent cycles	875 μs)
Update time for RT	
— for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes
— Shared device	Yes
Number of IO Controllers with shared device, max.	4
2. Interface	•
Interface types	Vara Via OM DD madula
RS 485      Number of ports	Yes; Via CM DP module
Number of ports	1
Protocols	Von
PROFIBUS DP devices	Yes
PROFIBUS DP device     SIMATIC communication	Yes
SIMATIC communication	Yes
PROFIBUS DP master	
Number of connections, max.	48
max. number of DP devices	125
Services	
— PG/OP communication	Yes
— Equidistance	No
— Isochronous mode	No
— activation/deactivation of DP devices	Yes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
<ul> <li>Autonegotiation</li> </ul>	Yes
<ul> <li>Autocrossing</li> </ul>	Yes
Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s

Protocols	
PROFIsafe	No
Number of connections	
Number of connections, max.	88
Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	88
Number of S7 routing paths	16
Redundancy mode	10
Media redundancy	
	only via 1st interface (X1)
— Media redundancy — MRP	
— MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms
<ul> <li>Number of stations in the ring, max.</li> </ul>	50
SIMATIC communication	
• S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as server     S7 communication, as client	Yes
User data per job, max.	
Open IE communication	See online help (S7 communication, user data size)
·	Von
TCP/IP      Data longth, max.	Yes 64 kbyto
— Data length, max.	64 kbyte
— several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user-defined pages
• HTTPS	Yes; Standard and user-defined pages
Further protocols	
• MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000
Number of simultaneously active program alarms	
<ul> <li>Number of program alarms</li> </ul>	300
<ul> <li>Number of alarms for system diagnostics</li> </ul>	100
<ul> <li>Number of alarms for motion technology objects</li> </ul>	80
Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 3 engineering systems
Status block	Yes; up to 8 simultaneously
Single step	No
Status/control	
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Number of variables, max.	inputor outputo, momory site, sees, distributed 1/05, timers, counters
of which status variables, max.	200; per job
— of which control variables, max.	200; per job
Forcing	Von
• Forcing	Yes
Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	

	V
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	4. Up to 540 VD of data anatomic and acceptate
Number of configurable Traces     Interrupts/diagnostics/status information	4; Up to 512 KB of data per trace are possible
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
Monitoring of the supply voltage (PWR-LED)	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	165
Motion Control	Yes
Speed-controlled axis	103
Number of speed-controlled axes, max.	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Positioning axis</li> </ul>	
<ul> <li>Number of positioning axes, max.</li> </ul>	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Synchronized axes (relative gear synchronization)</li> </ul>	
— Number of axes, max.	3; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
External encoders	
Number of external encoders, max.	6; Requirement: There must be no other motion technology objects created; note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
Controller	
<ul><li>PID_Compact</li></ul>	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
<ul> <li>Performance level according to ISO 13849-1</li> </ul>	none
SIL acc. to IEC 61508	No
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	0 °C
• horizontal installation, max.	60 °C
• vertical installation, min.	0 °C
• vertical installation, max.	50 °C
configuration / header	
configuration / programming / header	
Programming language — LAD	Yes
— FBD	Yes
— FBD — STL	Yes
— SCL	Yes
— GRAPH	
Know-how protection	
TATION TION DIOLECTION	Yes
·	
User program protection/password protection	Yes
User program protection/password protection     Copy protection	Yes
User program protection/password protection	Yes Yes Yes
<ul> <li>User program protection/password protection</li> <li>Copy protection</li> <li>Block protection</li> <li>Access protection</li> </ul>	Yes Yes Yes
<ul> <li>User program protection/password protection</li> <li>Copy protection</li> <li>Block protection</li> </ul>	Yes Yes Yes Yes Yes
User program protection/password protection Copy protection Block protection Access protection Protection level: Write protection	Yes Yes Yes Yes Yes Yes

• lower limit adjustable minimum cycle time • upper limit adjustable maximum cycle time Width 100 mm Height 117 mm Depth 75 mm Weights 310 g Weight, approx.

Version Classification eClass 14 27-24-26-07 12 27-24-26-07 eClass 27-24-26-07 eClass 9.1 eClass 9 27-24-26-07 eClass 8 27-24-26-07 27-24-26-07 eClass 7.1 27-24-26-07 eClass 6 ETIM EC001603 9 **ETIM** 8 EC001603 ETIM 7 EC001603 IDEA 3565 4

Approvals / Certificates

**General Product Approval** For use in hazardous locations

Manufacturer Declara-<u>tion</u>

**Miscellaneous** 



**Miscellaneous** 

UNSPSC



15

<u>FM</u>

32-15-17-05

Marine / Shipping

**Industrial Communication** 





Profibus

**PROFINET** 

last modified:

12/8/2024

